



1. TANK WILL BE APPROXIMATELY 9,500 GALLONS
2. CONTAINMENT DIMENSIONS ARE 10'x35' AND WILL PROVIDE 110% FOR VOLUMES BEING STORED
3. SHUT-OFF SWITCH WILL BE LOCATED AT EACH PUMP WITH AN EMERGENCY SWITCH OUTSIDE OF EACH BERM. A SECONDARY SHUT-OFF SWITCH WILL BE LOCATED REMOTELY IN THE WAREHOUSE OFFICE OVER 100' AWAY. SIGNS WILL INDICATE EMERGENCY SHUT-OFF INFORMATION.
4. THE PUMPS WILL BE LOCATED APPROXIMATELY 5' AWAY FROM THE TANKS AND PETROLEUM RATED HOSES WILL BE INSTALLED WITH AUTOMATIC SHUT-OFF NOZZLES.
5. THE PRODUCT TO BE DISPENSED WILL BE GASOLINE AND OR DIESEL TO BE CONSUMED BY ON-ROAD VEHICLES
6. IT SHOULD BE NOTED THAT THESE INSTALLATIONS ARE TEMPORARY AND WILL MEET THE REQUIREMENTS AND STANDARDS OF ALL FEDERAL, STATE AND LOCAL AGENCIES.
7. ALL DIMENSIONS ARE APPROXIMATE AND MAY BE MODIFIED AS NECESSARY TO SUIT ACTUAL SITE CONDITIONS

REVISIONS



PREPARED BY:  
TROW ENGINEERING CONSULTANTS, INC.  
7505 NW Tiffany Springs Pkwy., Suite 400  
Northpointe Circle I  
Kansas City, MO 64153  
Phone: 1-816-801-7063  
Fax: 1-816-801-7048



ORIGINATOR:	
<b>C. BUSH</b>	<b>06.12.09</b>
NAME	DATE
CHECKED BY:	APPROVED BY:
<b>TW</b>	<b>SS</b>

Figure 2.2.7-2			
FIA #	<b>1399</b>	CHAINAGE:	DISCIPLINE # <b>00</b>
TITLE			
<b>TYPICAL GASOLINE TANK ARRANGEMENT DETAIL</b>			
SCALE	<b>N.T.S.</b>	DWG No	<b>1399-00-ML-00-702</b>
		REV	

LAST PLOT DATE:  
Mon, 15 Jun 2009 - 3:49pm